




# EMERGENCY RECALL ORDER



The Pipeline and Hazardous Materials Safety Administration issued an emergency recall of 55,000+ propane cylinders manufactured by The Lite Cylinder Company.

**These cylinders may leak flammable gas or suddenly rupture.**

The full recall order is available at: <http://go.usa.gov/bbyV>



The affected cylinders may be marked in the location indicated above with any of the following numbers: M5729, DOT-SP 14562, DOT-SP 13957, DOT-SP 13105 (Only if manufactured by The Lite Cylinder Company. Cylinders manufactured by Composite Scandinavia [M0408] and marked with this number are not subject to the recall).

**In the absence of instructions from Lite Cylinder, PHMSA advises anyone possessing one of these cylinders to:**

- Stop using the cylinder(s)
- Close the valve(s)
- Safely disconnect the cylinders once the valves are closed
- Store the cylinder(s) in a space that is well ventilated and not enclosed
- Protect the cylinder(s) from heat and keep away from all heat sources

**WARNING: ATTEMPTS TO EMPTY THE CYLINDER OR REMOVE THE CYLINDER VALVE BY UNQUALIFIED PERSONS MAY LEAD TO SERIOUS INJURY OR DEATH**